

# VT series

**Ball Valve for Rail Applications** 


Installation and Maintenance Instructions






For further information,

FΝ



## **VT40 – INTERFACE VERSION**





#### **TECHNICAL DATA**

Fluid:	Com
Working pressure:	10 b
Maximum pressure:	12 b
Storage temperature:	-55
Operating temperature*:	-40
	* Air s
Materiale:	Bod

Materials

mpressed air bar (146 psig) bar (175 psig) °C to +85 °C (-67 ° to 185 °F) °C to +85 °C (-40 ° to 185 °F) supply must be dry enough to avoid ice formation at temperatures below +2 °C (+35 °F) Body, end connectors and handles: Aluminium Seat: PTFE 'O'-rings: Synthetic Rubber Ball. Stem: Brass Screws: Steel





EXTERNAL SWITCH KIT

INSTALLATION

The ball valve must be connected to the system so it respects the direction of flow shown on the body of ball valve. The plugs must be removed before use

# Inline Mounted Valves

Use pipe thread sealant on male threads only. Do not allow sealant to enter interior of valve

# Flange Mounted Valves

Attach valve to flange using screws + insert o-rings from attachment.

#### Disassembly

1. Shut off inlet pressure. Reduce pressure in inlet and outlet lines to zero.

2. Remove the valve from the air line. Disassemble in general accordance with item numbers on exploded view.

#### Cleaning

- 1. Clean all parts with warm water and soap.
- 2. Dry and inspect parts. Replace parts found to be damaged.


#### Assembly

1. Lubricate o-rings and seats (item 3, 4, 7, 30) with light coat suitable grease with temperature range -40°C to +85°C (the grease should be based on synthetic hydrocarbon oil and calcium soap).

2. Assemble the unit as shown on the exploded view. Ball (item 2) must be assembled so the drilled hole can be seen in the outlet when the handle is in the closed position.

#### Locking handle

Padlock with following recommended dimensions is to be used to lock the latching handle.



## 

These products are intended for general usage primarily for Rail sector. Do not use these products where pressures and temperatures can exceed those listed under Technical Data

Before using these products with fluids other than air, consult IMI Precision Engineering. The ball valve is meant to open/close working fluid supply, not for flow regulation. Electric monitoring provides information about actual working status just in end positions. This signal is for information only and should not be used as a safety signal. Before disassembling of device placed behind the valve, the operator needs to check the system is depressurized by separate pressure indicator (e.g. pressure switch), even the signal from monitoring shows closed position of the valve. The valve equipped by electrical monitoring needs to be grounded to ensure proper protection against electric shock. End user is responsible for correct grounding and wire protection against damage.

